

APPENDIX - VIII

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE

NO. 1413

DATE: 24/08/2020

It is certified that an inspection team headed by Rafendra Kumar
Sub engineer water supply (Name of Officers
with designation) from municipal corporation (Name of
Department/office) inspected the G.D. Goenka Public School,
Gram Jauwa Beni Ram near Rohilkhand University (Name & Address of
the school) on 13/07/2020 and found that the G.D. Goenka Public
School, Bareilly. (Name of the school) has safe
drinking water facilities for the students and members of staff of the institution and is maintaining the
hygienic sanitation condition in the school building & the campus as per the norms prescribed by the
Central /State /U.T govt.

The above valid for a period of 24/08/2020 to 23/08/2021

Signature with seal

Name

Designation

Water Testing Laboratory
U.P. Jal Nigam, Bareilly


Rafendra Kumar

Assistant engineer

To
G.D. Goenka Public School,
Gram Jauwa Beni Ram
Near Rohilkhand University Bareilly.

(Name & Address of the Institution)

CHAIRMAN
G.D. Goenka Public School
Bareilly





UTTAR PRADESH JAL NIGAM

WATER-TESTING LABORATORY, BAREILLY

PHYSICAL, CHEMICAL AND BACTERIOLOGICAL TEST – REPORT

Serial No. 36969

Dated 19 Aug 2020

Name of Town/Village with Code No Bareilly

Block / District

Location / Source of Sample

Location of the Source

Name and designation of the person responsible to collect the sample Sri Abhishek Srivastava (Principal)

Date and time of sampling

18.08.2020

Date of analysis

18.08.2020 to 19.08.2020

Parameters	Unit	Test Result	Indian Standards Acceptable Cause of rejection	
A) PHYSICAL EXAMINATION				
1. Taste		Sweet	Unobjectionable	Unobjectionable
2. Colour	Platinum Cobalt Scale	Colourless	5	2
3. Odour		Odourless	Unobjectionable	Unobjectionable
4. Turbidity	J. T. U.	0.0	2.50	1
5. pH	J. T. U.	7.3	7.00 TO 8.50	6.50 to 9.2
B) CHEMICAL ANALYSIS				
1. Total dissolved Solids	mg/l	240	500.00	1500.0
2. Chloride (as Cl)	mg/l	120	200.00	1000.0
3. Total Hardness (as CaCO ₃)	mg/l	96	200.00	600.0
4. Nitrate (NO ³) (as NO ₃)	mg/l	10	45.00	45.0
5. Fluoride (as F)	mg/l	0.5	1.00	1.5
6. Sulphate (as SO ₄)	mg/l	—	200.00	400.0
7. Residual Chlorine	mg/l	—	0.20	0.4
8. Iron (as Fe)	mg/l	0.1	0.10	1.0
9. Manganese (as Mn)	mg/l	—	0.05	—
C) BACTERIOLOGICAL EXAMINATION				
1. Faecal Coliforms	No/100 ml	—		
2. Coliform Organism	No/100 ml	—		

0

वरिष्ठ सहायक अभिकारी

प्रमाणित (बरेली)

वसिष्ठ नगर स्वयंसेवक अधिकारी
नगर प्रालिका परिषद (बरेली)
Water Testing Laboratory
U.P. Jal Nigam, Bareilly

Lab Assistant

CHEMIST/JUNIOR ENGINEER

CHAIRMAN
G.D. Goenka Public School
Bareilly

